



# PURCHASE REQUEST

DEPARTMENT OF FOREIGN AFFAIRS

Agency

Department:	OPAS - PMTD		PR No. :	Date: 7-Jan-12
Section :	ENGINEERING SECTION		SAI No.:	Date:
Stock No.	Unit	Item Description	QTY.	Unit Cost
	UNITS	<b>5TR SPLIT TYPE AC UNITS</b>  <b>SPECS:</b>  <b>1. FLOOR MOUNTED</b> <b>2. 3PHASE, 220 VOLTS</b> <b>3. 60 AMPS.</b>	2	
XX				
<b>SCOPE OF WORK:</b>  1. PROVIDE LABOR, EQUIPMENT, TOOLS AND MATERIALS. 2. DISMANTLING OF EXISTING DEFECTIVE SPLIT TYPE AC UNITS AT THE AREA AND TO BE DELIVERED TO DFA MAIN OFFICE. 3. SUPPLY AND INSTALLATION OF 2 UNITS OF BRAND NEW FLOOR MOUNTED SPLIT TYPE AC UNITS AT MIS SERVER ROOM, OCA BUILDING, ASEANA. 4. AC EQUIPMENT SHOULD BE ACCESSIBLE TO TECHNICIANS FOR MAINTENANCE PURPOSES. 5. INSTALLATION OF INDUSTRIAL GRADE OF COPPER REFRIGERANT PIPING SYSTEM MEASURING AT 220 FEET AND INSULATIONS PER 2 UNITS. 6. INSTALLATION OF INDUSTRIAL GRADE FILTER DRYER AND SYSTEM RE-PROCESS (VACUUMING, FLUSHING AND FREON CHARGING). USE ENV. FRIENDLY REFRIGERANT GAS. 7. INSTALLATION OF INDUSTRIAL GRADE FIELD THHN ELECTRICAL WIRINGS, INSULATIONS AND HIGH QUALITY CIRCUIT BREAKERS 60AMPS. FROM INDOOR TO OUTDOOR. 8. PROVIDE TECHNICAL SUPERVISION. 9. TESTING AND COMMISSIONING IN THE PRESENCE OF MR. PHILIP C. TABULA-Head Engineering Section. 10. HOUSKEEPING AND DEMOBILIZATION. 11. PROVIDE 1 YEAR WARRANTY AGAINST MATERIALS, AC EQUIPMENT AND WORKMANSHIP.  <b>APPROVED BY:</b>  <b>ALBERT F. DEL ROSARIO</b> Secretary of Foreign Affairs (Chargeable against PRF)				
			<b>TOTAL</b>	<b>Php. 300,000.00</b>
<b>Purpose:</b>  <b>FOR THE REPAIR / MAINTENANCE OF THE DFA BUILDING</b>				
Signature:	Certified Correct by:   <b>KERWIN ORVILLE C. TATE</b> Director, OPAS - PMTD		Recommend Approved by:   <b>MELITA S. STA. MARIA-THOMECZEK</b> Assistant Secretary, OPAS	
Printed Name:				
Designation:				

NOTE:  
FOR PHILGEPS BIDDING PLEASE.....

12/1/12